PURCHASE DESCRIPTION

SIGNAL GENERATOR (8 GHz to 20 GHz)

FSNTU-B

- 1.0 GENERAL This procurement requires a stable microwave signal generator capable of generating signals over the frequency range of 8 GHz to 20 GHz with external AM, internal and external FM, and Pulse modulation with delay capabilities.
- 2.0 CLASSIFICATION The equipment shall meet the requirements of MIL-T-28800(), Type III, Class 5, Style E, Color R for Navy shipboard, submarine, and shore applications with the following modifications and exceptions:
 - The Electromagnetic Interference requirements of MIL-T-28800() are limited to CE03, CS01, CS02 (0.05 to 100 MHz), CS06, RE02 (14 kHz to 10 GHz), and RS03.
 - b. The warm-up time is extended to one hour.
- 3.0 OPERATIONAL REQUIREMENTS The equipment shall be capable of generating signals within the parameters and accuracies specified herein.
- 3.1 **Frequency Characteristics**
- 3.1.1 Range: At least 8.0 GHz to 20.0 GHz
- 3.1.2 Resolution: At least 1 kHz; digital readout
- 3.1.3 Accuracy: Equal to reference standard (CW mode)
- 3.1.4 Stability (Equal to or better than limits specified below)
- 3.1.4.1 Internal: Less than 1 part in 109/h at 25°C ±5°C after one hour warmup
- 3.1.4.2 External: Equal to external standard
- 3.1.4.3 Temperature: Less than ±2 parts in 105 change over 0 to 50°C
- 3.1.5 Residual Modulation (CW mode in 50 Hz to 15 kHz detection BW)
- 3.1.5.1 FM: Less than 300 Hz rms
- AM: Less than 0.3% pk 3.1.5.2
- 3.1.6 Spectral Purity
- 3.1.6.1 Harmonics: < -55 dBc
- 3.1.6.2 Power line/Fan rotation related harmonics: < -40 dBc (< 1 kHz from carrier)
- 3.1.6.3 Non-harmonics/Spurious: < -55 dBc (≥ 10 kHz from carrier) (10 kHz offset from carrier)

1

3.1.6.4 Phase Noise: < -70 dBc/Hz

3.2	Output Characteristics {F = Output Frequency}		
3.2.1	Range: +10 to -90 dBm (minimum) +7 to -90 dBm (minimum)	[F < 18 GHz] [F > 18 GHz]	
3.2.2	RF Output: Leveled output +10 dBm or les	s [F < 18 GHz]; +7 dBm [F > 18 GHz]	
3.2.3	Accuracy: ±2.0 dB		
3.2.4	Display/Resolution: Digital display; minimum resolution of 0.1 dB		
3.2.5	Flatness: ±1.5 dB measured at an output level of 0 dBm		
3.2.6 3.2.6.1	Impedance/Connector: 50 ohms; type-N fe VSWR: < 2.5:1	emale connector or SMA [at levels < 0 dBm]	
3.2.7	Reverse Power Protection: The generator signal levels at its output connector or ext		
3.2.7.1	Average Power: 4 watts [F<12 GHz]; 1 wa		
3.2.7.1	Peak Power: 2.5 kilowatts [F<12 GHz][W	-	
3.3	Modulation Characteristics		
3.3.1	Pulse Modulation		
3.3.1.1	Internal		
3.3.1.1.1	Rate (PRF): At least 100 Hz to 1 MHz		
3.3.1.1.2	` ,		
3.3.1.1.3			
3.3.1.1.4			
3.3.1.1.5	Delay: At least 100 ns to 100 ms; accur	•	
3.3.1.1.5	•		
3.3.1.1.5		; width corresponds to PW control setting.	
3.3.1.1.6		at least 100 Hz to 50 kHz, provides sync rate for	
3.3.1.2	pulse modulation External		
3.3.1.2.1	Rate (PRF): At least 100 Hz to 1 MHz		
3.3.1.2.2	Width (PW): Greater than 0.1 µs		
3.3.1.2.3		ame PW and PRF as external input pulse	
3.3.1.2.4	Pulse Input: TTL compatible	and I W and I W as external input paise	
0.0.1.2.4	r disc input. The compatible		
3.3.2	Amplitude Modulation (AM) (Can be used s	imultaneously with pulse modulation}	
3.3.2.1	External		
3.3.2.1.1	Rate: At least 0.1 - 10 kHz		
3.3.2.1.2	•		
3.3.2.1.3	Sensitivity: At least 70%/V		

3.3.3	Frequency infodulation (Fivi) $\{F = \text{carrier freq } / \Delta F = \text{peak freq deviation} \}$	
3.3.3.1	Internal FM	
3.3.3.1.1	Rate: At least 1 kHz to 100 kHz	
3.3.3.1.2	FM Deviation: At least 10 kHz to 1 MHz peak	
3.3.3.1.3	FM Accuracy: ±20%	
3.3.3.1.4	Incidental AM: ≤7% (50 Hz - 15 kHz BW)[∆F = 100 kHz @ 10 kHz]	
3.3.3.2	External FM	
3.3.3.2.1	Rates: At least 1 kHz to 1 MHz	
3.3.3.2.2	FM Deviation: At least 10 kHz to 1 MHz peak	
3.3.3.2.3	FM Accuracy: ±20%	
3.3.3.2.4	Distortion: ≤ 10%	$[\Delta F = 100 \text{ kHz} @ 10 \text{ kHz}]$

4.0 GENERAL REQUIREMENTS

- 4.1 Power: 115 Vac \pm 10% single phase, 50, 60 or 400 Hz, and 230 Vac \pm 10% single phase, 50 and 60 Hz; 400 VA maximum
- 4.2 <u>Dimensions</u>: The total volume shall not exceed 39,400 cm³ (2,400 in³).
- 4.3 Weight: The overall weight shall not exceed 22.7 kg (50 lb).
- 4.4 <u>Calibration Interval</u>: The calibration interval shall be 12 months minimum. The equipment shall be within all accuracy requirements specified herein, with a 72% or greater confidence factor following a calibration interval of 12 months.
- 4.5 Remote Operation: The unit will be capable of remote operation via IEEE-488() bus interface. At a minimum it shall operate as a listener such that all major functions except the power on/off switch are controllable and shall have as a minimum the following subset of GPIB commands: AH1, SH1, L4.